




# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name: Regupol Aktiv Core Series #AK10100**

Product Sample Information		Certificate Information	
Manufacturer:	Regupol America LLC	Certificate No:	130227-02
Manf. Website:	www.regupol.com	Certified By:	
CSI Category & No.:	Rubber Sheet Flooring (096516-Rubber)		Raja S. Tannous, Laboratory Director
Date Produced:	1/30/2013	Date:	February 27, 2013

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.1, 2010 (Emission testing method for CA Specification 01350)

### Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>	
	Criterion	Compliant?	Criterion	Compliant?
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.1-2010)

2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)

3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (*ibid.*).

### Potential Applications

- CALGreen, CA Code of Regulations Title 24, Part II, 2010, Sections 4.504.4/5.504.4.6: Resilient Flooring Systems
- ANSI/ASHRAE/USGBC/IES Standard 189.1-2009, Section 8.4.2.3: Floor Covering Materials
- USGBC LEED CI, NC, Schools, 2009, IEQ Credit 4.3: LEM - Flooring Systems
- USGBC LEED for Healthcare, 2009 (Feb 2011), IEQ Credit 4: LEM, Group 3 - Flooring
- Collaborative for High Performance Schools (CHPS) rating system, 2009 Criteria EQ2.2.3: Flooring Systems
- Green Guide for Healthcare, V2.2, 2007, EQ Credit 4.3: LEM - Flooring Systems

**Narrative:** Regupol America LLC selected a sample representative of its Regupol Aktiv Core Series #AK10100 product and submitted it for testing commencing on 2/1/2013. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.1-2010. The results of the test are presented in Berkeley Analytical report, 590-004-02A-Feb2713.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

**DISCLAIMER:** THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.